



RIASSUNTO RAPPORTI ANALISI 2018

DATA PRELIEVI	26.07.2018		26.07.2018		21.06.2018		21.06.2018	
Luogo	Fontana Molina Buseno	Valore tolleranza	Serbatoio Toga Buseno	Valore tolleranza	Fontanon San Vittore	Valore tolleranza	Salzin San Vittore	Valore tolleranza
ANALISI MICROBIOLOGICA								
Germi aerobi, mesofili	5 UFC / ml	300 UFC / mL	0 UFC / ml	20 UFC / ml	< 10 UFC / ml	20 UFC / ml	< 10 UFC / ml	20 UFC / ml
Escherichia coli	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml
Enterococchi	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml	0 UFC / 100 ml
ANALISI FISICO CHIMICA								
pH	6.80		6.99					
Conduttività	48 mcS/cm		43 mcS / cm					
Temperatura	12 °C		9 °C		5.4 °C		5.4 °C	
Valutazione	inaccettabile		inaccettabile		inaccettabile		inaccettabile	

6542 Buseno, 28 novembre 2018